



012

CERTIFICATE OF REGISTRATION

This is to certify that

Warm Springs Composite Products

PO Box 906
Warm Springs
OR 97761
USA

Meets the requirements of the BM TRADA **Q-Mark Fire Door
Manufacture** scheme to **STD 006**

Robert Veitch
Executive Vice President Fire & Building Products
Element Materials Technology

Certificate Number

317

Date of Initial Certification

22 September 2008

Date of Last Issue

24 February 2021

Date of Expiry

21 September 2023

Warringtonfire Testing and Certification Limited t/a BM TRADA, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 10 Lower Grosvenor Place, London, SW1W 0EN, UK.
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com

Registration Schedule

Branch

Warm Springs Composite Products

Address

PO Box 906, Warm Springs, OR 97761,
USA

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
Chilt/A06218	F	Warm Springs Composite Products	60 min Fire Resisting Doorsets* (Glazed or unglazed)	60 min	BS476 Part 22
Chilt/A06218	F	Warm Springs Composite Products	90 min Fire Resisting Doorsets* (Glazed or unglazed)	90 min	BS476 Part 22
Chilt/A06218	F	Warm Springs Composite Products	120 min Fire Resisting Doorsets* (Glazed or unglazed)	120 min	BS476 Part 22

* Constructed from WSCP Tectonite and WSCP Mineral Cores supplied in kit form for further processing by doorset manufacturers based on the cascaded Global Assessments listed.

Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of FoA Report	Doorset Description	Rating	Test Type
NONE	-	-	-	-

Test Reports

Test reports cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
NONE	-	-	-	-